

- BEFORE CHANGING BULB OR HANDLING FIXTURE.
- VERIFY THAT SUPPLY VOLTAGE IS CORRECT BY COMPARING IT WITH THE LUMINAIRE LABEL INFORMATION.
 ALL WIRING CONNECTIONS SHOULD BE CAPPED WITH UL APPROVED WIRE CONNECTORS.

INSTALLATION (ALWAYS TURN OFF THE POWER SUPPLY FROM MAIN CIRCUIT BREAKER FIRST!)

CHAIN SUSPENDING MOUNT

flexible metallic conduit (provided by others)

Installation Steps:

Always turn off the power supply from main circuit breaker first!

- Remove the LED fixture from packaging and inspect for any damages. Handle LED fixture with care.
- TO INSTALL WITH CHAIN MOUNT: 1 nstall the chain into the provided wire hanger. Secure the other end of the chain to a structure using hardware rated for the load. Install the wire hanger into the slots on the top of the LED luminaire end piece. Make sure the wiring hangers are fully engaged into the slots on the top channel.
- Connect the LED high bay wiring to incoming power lines refer to the General Wiring Diagram. Use only UL listed wir e.
 NOTE: The purple and pink wires inside the driver compartment are 0-10V (low voltage) dimming wires.
 Connect to low voltage wiring only.
- Clean all residues and fingerprints from the LED luminaire. Double check all hanging hardware before moving onto the next installation.

CABLE SUSPENDING MOUNT



General Wiring Diagram



Clean all residues/fingerprints from the new LED high bay and lens. Double check all hanging hardware before moving onto the next installation.

www.portorlighting.com



PT-LHTL-185-2C3P / PT-LHTL-270-2C3P PT-LHTL-400-2C3P



INSTALLATION (ALWAYS TURN OFF THE POWER SUPPLY FROM MAIN CIRCUIT BREAKER FIRST!)

SURFACE MOUNTING

Always turn off the power supply from main circuit breaker first!

1. Fix the surface mount bracket to celling with adequate screws.



2. Fix the fixture to the bracket with adequate screws.



3. Connect the main power wires to fixture wires refer to General Wiring Diagram .All wire connectors or terminal caps must be left inside the junction box or fixture driver box.



CLEANING & MAINTENANCE

CAUTION: Be sure fixture temperature is cool enough to touch. Do not clean or maintain while fixture is energized.

1Lens can be washed only after emoving from fixture and only in a solution of warm water and any mild, non abrasive household detergent, rinsed with clean water and wiped dry. Do not use chemicals to clean Lens or fixture.

2. Do not open fixture to clean the LED. Do not touch the LED.

TROUBLESHOOTING

1. Check that the line voltage at fixture is correct. Refer to wiring directions.

2. Be sure the fixture is grounded properly .

Clean all residues/fingerprints from the new LED high bay and lens. Double check all hanging hardware before moving onto the next installation.

www.portorlighting.com

Specification subject to change without notice



PT-LHTL-185-2C3P / PT-LHTL-270-2C3P PT-LHTL-400-2C3P



INSTALLATION (ALWAYS TURN OFF THE POWER SUPPLY FROM MAIN CIRCUIT BREAKER FIRST!)

PENDANT MOUNTING

Always turn off the power supply from main circuit breaker first!

- 1. Attach the pendant box to conduit pipe.
- 2. Fix the fixture onto the pendant box with screws.



3. Make wiring connections refer to General Wiring Diagram. The bridged wires must be UL listed and wrapped with flexible protective conduit.



4. Install the two side-covers of the bracket with screws to hide the wires.





Note: If the outlet board located under the pendant box, do wiring connection directly in the box and no need to use the flexible protective conduitAll wire connectors or terminal caps should be left inside the pendant box.

Clean all residues/fingerprints from the new LED high bay and lens. Double check all hanging hardware before moving onto the next installation.





PT-LHTL-185-2C3P / PT-LHTL-270-2C3P PT-LHTL-400-2C3P



INSTALLATION (ALWAYS TURN OFF THE POWER SUPPLY FROM MAIN CIRCUIT BREAKER FIRST!)

WIRE GUARDS MOUNTING

1.Prepare the package of lamp body and accessories.



3.Fasten the chips by screws into the prepunched holes of fixture body.

2.Insert the provided chips(4 pcs) onto the wire guard.



4. The installation is completed.





ADDITIONAL ACCESSORIES

Step 1:Remove the receptacle cover.(Figure 1 and Figure 2)Step 2:Insert sensor into the audio jack and turn the sensor clockwise to tightly secure the sensor.(Figure 3 and Figure 4)

- DC 12V Sensor
- ANT-6-4T

General Wiring Diagram LED+ Red Blue LED Black Purple SIMON DRIVER DIM-Figure 2 Figure 1 Pink White DIM N 0-Yellow 12VDC+ Recentar LED Light Source Sensor Figure 4 Figure 3

Clean all residues/fingerprints from the new LED high bay and lens. Double check all hanging hardware before moving onto the next installation.

Specification subject to change without notice



PT-LHTL-185-2C3P / PT-LHTL-270-2C3P PT-LHTL-400-2C3P



INSTALLATION (ALWAYS TURN OFF THE POWER SUPPLY FROM MAIN CIRCUIT BREAKER FIRST!)

DIFFUSER REPLACEMENT

1. Remove the screw of one end-cover.

2. Remove the end-cover.





3. Take out the diffuser directly.

4. Put the desired diffuser into the chanel.





6. The replacement is completed .

5. Reattach the end-cover to the fixture body and fix it with screw .



Clean all residues/fingerprints from the new LED high bay and lens. Double check all hanging hardware before moving onto the next installation.

Specification subject to change without notice